



Pace Analytical Services, LLC
1168 Whigham Place
Tuscaloosa, AL 35405
(205) 614-6630

February 04, 2025

Mr. Napoleon Wilks IV
City of Prattville
101 W. Main Street
Prattville, AL 36067

RE: Project: Artesian Well PFAS
Pace Project No.: 20339504

Dear Mr. IV:

Enclosed are the analytical results for sample(s) received by the laboratory on December 05, 2024. The results relate only to the samples included in this report.

The test results provided in this final report were generated by each of the following laboratories within the Pace Network:

- Pace Analytical Services - Ormond Beach

If you have any questions concerning this report, please feel free to contact me.

Sincerely,

A handwritten signature in blue ink that reads "Cinnamon Mitchell" with a stylized flourish at the end.

Cinnamon Mitchell for
Cindy Simpson
cindy.simpson@pacelabs.com
(205)614-6630
Project Manager

Enclosures

cc: Doug Smedley, Prattville Wastewater

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



CERTIFICATIONS

Project: Artesian Well PFAS

Pace Project No.: 20339504

Pace Analytical Services Ormond Beach

8 East Tower Circle, Ormond Beach, FL 32174

Alaska DEC- CS/UST/LUST

Alabama Certification #: 41320

California Certification# 3096

Colorado Certification: FL NELAC Reciprocity

Connecticut Certification #: PH-0216

Delaware Certification: FL NELAC Reciprocity

DoD-ANAB #:ADE-3199

Florida Certification #: E83079

Georgia Certification #: 955

Guam Certification: FL NELAC Reciprocity

Hawaii Certification: FL NELAC Reciprocity

Illinois Certification #: 200068

Indiana Certification: FL NELAC Reciprocity

Kansas Certification #: E-10383

Kentucky Certification #: 90050

Louisiana Certification #: FL NELAC Reciprocity

Louisiana Environmental Certificate #: 05007

Maine Certification #: FL01264

Maryland Certification: #346

Massachusetts Certification #: M-FL1264

Michigan Certification #: 9911

Mississippi Certification: FL NELAC Reciprocity

Missouri Certification #: 236

Montana Certification #: Cert 0074

Nebraska Certification: NE-OS-28-14

Nevada Certification: FL NELAC Reciprocity

New Hampshire Certification #: 2958

New Jersey Certification #: FL022

New York Certification #: 11608

North Carolina Environmental Certificate #: 667

North Carolina Certification #: 12710

North Dakota Certification #: R-216

Ohio DEP 87780

Oklahoma Certification #: D9947

Pennsylvania Certification #: 68-00547

Puerto Rico Certification #: FL01264

South Carolina Certification: #96042001

Tennessee Certification #: TN02974

Texas Certification: FL NELAC Reciprocity

US Virgin Islands Certification: FL NELAC Reciprocity

Utah

Utah FL NELAC Reciprocity

Virginia Environmental Certification #: 460165

West Virginia Certification #: 9962C

Wisconsin Certification #: 399079670

Wyoming (EPA Region 8): FL NELAC Reciprocity

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE SUMMARY

Project: Artesian Well PFAS
Pace Project No.: 20339504

Lab ID	Sample ID	Matrix	Date Collected	Date Received
20339504001	Artesian Well	Drinking Water	12/05/24 13:00	12/05/24 15:06
20339504002	Field Blank	Drinking Water	12/05/24 13:00	12/05/24 15:06

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



SAMPLE ANALYTE COUNT

Project: Artesian Well PFAS
Pace Project No.: 20339504

Lab ID	Sample ID	Method	Analysts	Analytes Reported	Laboratory
20339504001	Artesian Well	EPA 537.1	TMM1	22	PASI-O
20339504002	Field Blank	EPA 537.1	TMM1	22	PASI-O

PASI-O = Pace Analytical Services - Ormond Beach

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: Artesian Well PFAS

Pace Project No.: 20339504

Sample: Artesian Well		Lab ID: 20339504001		Collected: 12/05/24 13:00		Received: 12/05/24 15:06		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
537.1 PFAS Compounds, Water									
Analytical Method: EPA 537.1 Preparation Method: EPA 537.1									
Pace Analytical Services - Ormond Beach									
11CI-PF3OUdS	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	763051-92-9	
9CI-PF3ONS	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	756426-58-1	
ADONA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	919005-14-4	
HFPO-DA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	13252-13-6	
NEtFOSAA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	2991-50-6	
NMeFOSAA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	2355-31-9	
PFBS	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	375-73-5	
PFDA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	335-76-2	
PFHxA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	307-24-4	
PFDoA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	307-55-1	
PFHpA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	375-85-9	
PFHxS	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	355-46-4	
PFNA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	375-95-1	
PFOS	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	1763-23-1	
PFOA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	335-67-1	
PFTeDA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	376-06-7	
PFTrDA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	72629-94-8	
PFUnA	ND	ug/L	0.0021		1	12/10/24 12:10	12/10/24 21:26	2058-94-8	
Surrogates									
13C2-PFDA (S)	97	%	70-130		1	12/10/24 12:10	12/10/24 21:26		
13C2-PFHxA (S)	100	%	70-130		1	12/10/24 12:10	12/10/24 21:26		
NEtFOSAA-d5 (S)	94	%	70-130		1	12/10/24 12:10	12/10/24 21:26		
HFPO-DAS (S)	98	%	70-130		1	12/10/24 12:10	12/10/24 21:26		

Sample: Field Blank		Lab ID: 20339504002		Collected: 12/05/24 13:00		Received: 12/05/24 15:06		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
537.1 PFAS Compounds, Water									
Analytical Method: EPA 537.1 Preparation Method: EPA 537.1									
Pace Analytical Services - Ormond Beach									
11CI-PF3OUdS	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	763051-92-9	
9CI-PF3ONS	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	756426-58-1	
ADONA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	919005-14-4	
HFPO-DA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	13252-13-6	
NEtFOSAA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	2991-50-6	
NMeFOSAA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	2355-31-9	
PFBS	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	375-73-5	
PFDA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	335-76-2	
PFHxA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	307-24-4	
PFDoA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	307-55-1	
PFHpA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	375-85-9	
PFHxS	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	355-46-4	
PFNA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	375-95-1	

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



ANALYTICAL RESULTS

Project: Artesian Well PFAS
Pace Project No.: 20339504

Sample: Field Blank		Lab ID: 20339504002		Collected: 12/05/24 13:00		Received: 12/05/24 15:06		Matrix: Drinking Water	
Parameters	Results	Units	Report Limit	Reg. Limit	DF	Prepared	Analyzed	CAS No.	Qual
537.1 PFAS Compounds, Water		Analytical Method: EPA 537.1 Preparation Method: EPA 537.1 Pace Analytical Services - Ormond Beach							
PFOS	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	1763-23-1	
PFOA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	335-67-1	
PFTeDA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	376-06-7	
PFTrDA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	72629-94-8	
PFUnA	ND	ug/L	0.0019		1	12/10/24 12:10	12/10/24 21:42	2058-94-8	
Surrogates									
13C2-PFDA (S)	96	%	70-130		1	12/10/24 12:10	12/10/24 21:42		
13C2-PFHxA (S)	100	%	70-130		1	12/10/24 12:10	12/10/24 21:42		
NEtFOSAA-d5 (S)	94	%	70-130		1	12/10/24 12:10	12/10/24 21:42		
HFPO-DAS (S)	98	%	70-130		1	12/10/24 12:10	12/10/24 21:42		

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: Artesian Well PFAS

Pace Project No.: 20339504

QC Batch: 1062025

QC Batch Method: EPA 537.1

Analysis Method: EPA 537.1

Analysis Description: 537.1 PFOA Compounds, Water

Laboratory: Pace Analytical Services - Ormond Beach

Associated Lab Samples: 20339504001, 20339504002

METHOD BLANK: 5834918

Matrix: Water

Associated Lab Samples: 20339504001, 20339504002

Parameter	Units	Blank Result	Reporting Limit	Analyzed	Qualifiers
11CI-PF3OUdS	ug/L	ND	0.0020	12/10/24 18:46	
9CI-PF3ONS	ug/L	ND	0.0020	12/10/24 18:46	
ADONA	ug/L	ND	0.0020	12/10/24 18:46	
HFPO-DA	ug/L	ND	0.0020	12/10/24 18:46	
NEtFOSAA	ug/L	ND	0.0020	12/10/24 18:46	
NMeFOSAA	ug/L	ND	0.0020	12/10/24 18:46	
PFBS	ug/L	ND	0.0020	12/10/24 18:46	
PFDA	ug/L	ND	0.0020	12/10/24 18:46	
PFDaA	ug/L	ND	0.0020	12/10/24 18:46	
PFHpA	ug/L	ND	0.0020	12/10/24 18:46	
PFHxA	ug/L	ND	0.0020	12/10/24 18:46	
PFHxS	ug/L	ND	0.0020	12/10/24 18:46	
PFNA	ug/L	ND	0.0020	12/10/24 18:46	
PFOA	ug/L	ND	0.0020	12/10/24 18:46	
PFOS	ug/L	ND	0.0020	12/10/24 18:46	
PFTeDA	ug/L	ND	0.0020	12/10/24 18:46	
PFTrDA	ug/L	ND	0.0020	12/10/24 18:46	
PFUnA	ug/L	ND	0.0020	12/10/24 18:46	
13C2-PFDA (S)	%	89	70-130	12/10/24 18:46	
13C2-PFHxA (S)	%	99	70-130	12/10/24 18:46	
HFPO-DAS (S)	%	93	70-130	12/10/24 18:46	
NEtFOSAA-d5 (S)	%	88	70-130	12/10/24 18:46	

LABORATORY CONTROL SAMPLE: 5834919

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
11CI-PF3OUdS	ug/L	0.0076	0.0073	96	70-130	
9CI-PF3ONS	ug/L	0.0075	0.0074	99	70-130	
ADONA	ug/L	0.0076	0.0078	104	70-130	
HFPO-DA	ug/L	0.008	0.0084	104	70-130	
NEtFOSAA	ug/L	0.008	0.0074	93	70-130	
NMeFOSAA	ug/L	0.008	0.0078	97	70-130	
PFBS	ug/L	0.0071	0.0070	99	70-130	
PFDA	ug/L	0.008	0.0079	99	70-130	
PFDaA	ug/L	0.008	0.0077	96	70-130	
PFHpA	ug/L	0.008	0.0081	102	70-130	
PFHxA	ug/L	0.008	0.0086	108	70-130	
PFHxS	ug/L	0.0073	0.0075	103	70-130	
PFNA	ug/L	0.008	0.010	125	70-130	

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: Artesian Well PFAS

Pace Project No.: 20339504

LABORATORY CONTROL SAMPLE: 5834919

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
PFOA	ug/L	0.008	0.010	130	70-130	
PFOS	ug/L	0.0074	0.0077	104	70-130	
PFTeDA	ug/L	0.008	0.0078	98	70-130	
PFTrDA	ug/L	0.008	0.0079	99	70-130	
PFUnA	ug/L	0.008	0.0081	101	70-130	
13C2-PFDA (S)	%			98	70-130	
13C2-PFHxA (S)	%			104	70-130	
HFPO-DAS (S)	%			98	70-130	
NEtFOSAA-d5 (S)	%			95	70-130	

LABORATORY CONTROL SAMPLE: 5834920

Parameter	Units	Spike Conc.	LCS Result	LCS % Rec	% Rec Limits	Qualifiers
11Cl-PF3OUdS	ug/L	0.0019	.0018J	97	50-150	
9Cl-PF3ONS	ug/L	0.0019	.0018J	95	50-150	
ADONA	ug/L	0.0019	.0019J	100	50-150	
HFPO-DA	ug/L	0.002	0.0021	104	50-150	
NEtFOSAA	ug/L	0.002	ND	99	50-150	
NMeFOSAA	ug/L	0.002	.0018J	90	50-150	
PFBS	ug/L	0.0018	.0017J	96	50-150	
PFDA	ug/L	0.002	.0019J	97	50-150	
PFDoA	ug/L	0.002	.0019J	97	50-150	
PFHpA	ug/L	0.002	0.0020	102	50-150	
PFHxA	ug/L	0.002	0.0022	108	50-150	
PFHxS	ug/L	0.0018	.0019J	102	50-150	
PFNA	ug/L	0.002	0.0024	118	50-150	
PFOA	ug/L	0.002	0.0026	128	50-150	
PFOS	ug/L	0.0019	.0019J	102	50-150	
PFTeDA	ug/L	0.002	ND	97	50-150	
PFTrDA	ug/L	0.002	.0019J	96	50-150	
PFUnA	ug/L	0.002	ND	96	50-150	
13C2-PFDA (S)	%			94	70-130	
13C2-PFHxA (S)	%			100	70-130	
HFPO-DAS (S)	%			95	70-130	
NEtFOSAA-d5 (S)	%			92	70-130	

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 5834921

5834922

Parameter	Units	35923236001		MS		MSD		MS		MSD		% Rec Limits	RPD	Max RPD	Qual
		Result	Conc.	Spike Conc.	Conc.	Result	Conc.	% Rec	Result	% Rec	Conc.				
11Cl-PF3OUdS	ug/L	1.6U ng/L	0.15	0.15	0.15	0.14	0.14	93	94	94	70-130	4	30		
9Cl-PF3ONS	ug/L	1.2U ng/L	0.15	0.15	0.15	0.14	0.14	96	94	94	70-130	1	30		
ADONA	ug/L	0.74U ng/L	0.15	0.15	0.15	0.14	0.15	97	95	95	70-130	1	30		

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA

Project: Artesian Well PFAS

Pace Project No.: 20339504

MATRIX SPIKE & MATRIX SPIKE DUPLICATE: 5834921 5834922												
Parameter	Units	35923236001 Result	MS Spike Conc.	MSD Spike Conc.	MS Result	MSD Result	MS % Rec	MSD % Rec	% Rec Limits	RPD	Max RPD	Qual
HFPO-DA	ug/L	1.7U ng/L	0.16	0.16	0.16	0.16	99	97	70-130	1	30	
NEtFOSAA	ug/L	0.95U ng/L	0.16	0.16	0.14	0.14	87	89	70-130	4	30	
NMeFOSAA	ug/L	1.6U ng/L	0.16	0.16	0.15	0.15	93	91	70-130	1	30	
PFBS	ug/L	0.68U ng/L	0.14	0.14	0.13	0.13	95	93	70-130	1	30	
PFDA	ug/L	0.99U ng/L	0.16	0.16	0.15	0.15	97	95	70-130	0	30	
PFDoA	ug/L	1.5U ng/L	0.16	0.16	0.15	0.15	94	95	70-130	3	30	
PFHpA	ug/L	1.0U ng/L	0.16	0.16	0.15	0.16	97	95	70-130	2	30	
PFHxA	ug/L	1.3U ng/L	0.16	0.16	0.16	0.16	101	99	70-130	1	30	
PFHxS	ug/L	0.75U ng/L	0.14	0.15	0.14	0.14	95	93	70-130	1	30	
PFNA	ug/L	2.0U ng/L	0.16	0.16	0.15	0.16	97	96	70-130	1	30	
PFOA	ug/L	0.90U ng/L	0.16	0.16	0.15	0.16	98	97	70-130	1	30	
PFOS	ug/L	1.2U ng/L	0.15	0.15	0.14	0.14	95	93	70-130	1	30	
PFTeDA	ug/L	1.9U ng/L	0.16	0.16	0.15	0.15	93	95	70-130	5	30	
PFTrDA	ug/L	1.8U ng/L	0.16	0.16	0.15	0.15	93	94	70-130	4	30	
PFUnA	ug/L	2.0U ng/L	0.16	0.16	0.15	0.15	96	94	70-130	0	30	
13C2-PFDA (S)	%						98	92	70-130			
13C2-PFHxA (S)	%						102	98	70-130			
HFPO-DAS (S)	%						100	96	70-130			
NEtFOSAA-d5 (S)	%						90	88	70-130			

Results presented on this page are in the units indicated by the "Units" column except where an alternate unit is presented to the right of the result.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALIFIERS

Project: Artesian Well PFAS
Pace Project No.: 20339504

DEFINITIONS

DF - Dilution Factor, if reported, represents the factor applied to the reported data due to dilution of the sample aliquot.

ND - Not Detected at or above adjusted reporting limit.

TNTC - Too Numerous To Count

J - Estimated concentration above the adjusted method detection limit and below the adjusted reporting limit.

MDL - Adjusted Method Detection Limit.

PQL - Practical Quantitation Limit.

RL - Reporting Limit - The lowest concentration value that meets project requirements for quantitative data with known precision and bias for a specific analyte in a specific matrix.

S - Surrogate

1,2-Diphenylhydrazine decomposes to and cannot be separated from Azobenzene using Method 8270. The result for each analyte is a combined concentration.

Consistent with EPA guidelines, unrounded data are displayed and have been used to calculate % recovery and RPD values.

LCS(D) - Laboratory Control Sample (Duplicate)

MS(D) - Matrix Spike (Duplicate)

DUP - Sample Duplicate

RPD - Relative Percent Difference

NC - Not Calculable.

SG - Silica Gel - Clean-Up

U - Indicates the compound was analyzed for, but not detected.

N-Nitrosodiphenylamine decomposes and cannot be separated from Diphenylamine using Method 8270. The result reported for each analyte is a combined concentration.

Reported results are not rounded until the final step prior to reporting. Therefore, calculated parameters that are typically reported as "Total" may vary slightly from the sum of the reported component parameters.

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



QUALITY CONTROL DATA CROSS REFERENCE TABLE

Project: Artesian Well PFAS

Pace Project No.: 20339504

Lab ID	Sample ID	QC Batch Method	QC Batch	Analytical Method	Analytical Batch
20339504001	Artesian Well	EPA 537.1	1062025	EPA 537.1	1062238
20339504002	Field Blank	EPA 537.1	1062025	EPA 537.1	1062238

REPORT OF LABORATORY ANALYSIS

This report shall not be reproduced, except in full,
without the written consent of Pace Analytical Services, LLC.



Project #
Project Manager:
Client:



Date and Initials of person:
Examining contents: oo
Verifying pH: _____

Thermometer Used: TUTM13 Date: 12/15/24 Time: 1506 Initials: STR

State of Origin: _____ ☐ For WV projects, all containers verified to $\leq 6^{\circ}\text{C}$

Cooler #1 Temp. $^{\circ}\text{C}$ 5.6 (Visual) 0 (Correction Factor) 5.6 (Actual)
Cooler #2 Temp. $^{\circ}\text{C}$ _____ (Visual) _____ (Correction Factor) _____ (Actual)
Cooler #3 Temp. $^{\circ}\text{C}$ _____ (Visual) _____ (Correction Factor) _____ (Actual)
Cooler #4 Temp. $^{\circ}\text{C}$ _____ (Visual) _____ (Correction Factor) _____ (Actual)
Cooler #5 Temp. $^{\circ}\text{C}$ _____ (Visual) _____ (Correction Factor) _____ (Actual)
Cooler #6 Temp. $^{\circ}\text{C}$ _____ (Visual) _____ (Correction Factor) _____ (Actual)

☒ Samples on ice, cooling process has begun.
☐ Samples on ice, cooling process has begun.
☐ Samples on ice, cooling process has begun.
☐ Samples on ice, cooling process has begun.
☐ Samples on ice, cooling process has begun.
☐ Samples on ice, cooling process has begun.

Recheck for QOT $^{\circ}\text{C}$ _____ (Visual) _____ (Correction Factor) _____ (Actual)

Time: _____ Initials: _____

Courier: ☐ Fed Ex ☐ UPS ☐ USPS ☐ Client ☐ Commercial ☒ Pace ☐ Other: _____

Shipping Method: ☐ Standard Overnight ☐ First Overnight ☐ Priority Overnight ☐ Ground ☐ International Priority ☐ Other: _____

Billing: ☐ Recipient ☐ Sender ☐ Third Party ☐ Credit Card ☐ Unknown

Tracking # _____

Custody Seal Present: ☐ Yes ☒ No Seal properly placed and intact: ☐ Yes ☒ No

Ice: ☒ Wet ☐ Blue ☐ Dry ☐ None ☐ Melted

Packing Material: ☐ Bubble Wrap ☐ Bubble Bags ☒ None ☐ Other: _____

Samples shorted to lab: ☐ Yes ☐ No (If yes, complete the following)

Shorted Date: _____

Shorted Time: _____

Bottle Quantity / Type: _____

Chain of Custody:	Present: ☒ Yes ☐ No Filled Out: ☒ Yes ☐ No ☐ N/A Sampler Name: ☒ Yes ☐ No ☐ N/A	
	Relinquished To Pace: ☒ Yes ☐ No ☐ N/A Sampling Date(s): ☒ Yes ☐ No ☐ N/A Sampling Time(s): ☒ Yes ☐ No ☐ N/A	
Samples Arrived within Hold Time.	☒ Yes ☐ No ☐ N/A	Comments:
Rush Turnaround Requested on COC.	☐ Yes ☒ No ☐ N/A	Comments:
Sufficient Volume.	☒ Yes ☐ No ☐ N/A	Comments:
Correct Containers Used.	☒ Yes ☐ No ☐ N/A	Comments:
Containers Intact.	☒ Yes ☐ No ☐ N/A	Comments:
Sample Labels Match COC (Sample ID, Date/Time of Collection).	☐ Yes ☒ No ☐ N/A	Comments: <u>Blank</u>
All containers needing acid / base preservation have been checked.	☐ Yes ☐ No ☒ N/A	Preservation Information Preservative: _____ Date: _____ Lot / Trace: _____ Time: _____ Amount added (mL): _____ Initials: _____
All containers needing preservation are found to be in compliance with EPA recommendation:	☐ Yes ☐ No ☒ N/A	
Exceptions: Vials, Microbiology, O&G, PFAS		
Headspace in Volatile Vials? (>6mm):	☐ Yes ☐ No ☒ N/A	
Trip Blank Present:	☐ Yes ☐ No ☒ N/A	

Comments / Resolutions (use back for additional comments):

Labeled by: o

Reviewed by: UT

Delivered by: oo